



GENERAL NOTES:

- 1) ALL PIPE FROM RISER TO REGULATOR INLET MUST BE WELDED.
- 2) GAS METER LOCATIONS AND GAS PIPING SHALL BE INSTALLED PER CHAPTER 12 OF UPC AND LBE STANDARDS.
- 3) METER ROOM MUST HAVE A 7 FT. MINIMUM FLOOR TO CEILING HEIGHT.
- 4) MUST CONFORM TO UMC 1309.0, UPC 1209.0, UFC 1106, AND DOT 49 CFR Ch. 1, PART 192.353d, 357d, 365b.
- 5) ALL ELECTRIC FIXTURES MUST BE EXPLOSION PROOF.
- 6) ALL ELECTRICAL AND MECHANICAL EQUIPMENT MUST BE APPROVED BY LBE BEFORE INSTALLATION IN METER ROOM IN ACCORDANCE WITH ARTICLE 500 OF NEC.
- 7) LBE APPROVED L.E.L. DETECTOR MUST BE INSTALLED AND TESTED BEFORE GASSING OF SYSTEM.
- 8) METER ROOM MUST NOT VENT INTO BUILDING OR ADJOINING CLOSED SPACES.